

Redacted non responsive

EPA#	PWS NAME	ETT Score	Sys has Tier 1 viols?	PWS Type	Pop Srvd	CONTAMIN.	Date 1st Significant (>=11)	Total RTCd Pts	On Path to Compliance?	SITE VISIT	COMMENTS
KS2015501	PRETTY PRAIRIE, CITY OF	194	Y	CWS	681	Nitrate	10/01/2009	2	Not on Path	1/25/2012- Zach Phillips	Pretty Prairie's source of water is ground water. The PWS has 1 well and 1 TP. Most recent nitrate violation occurred 1st quarter 2013 with a result of 19.0 mg/l. KDHE defers the City's request for a meeting to EPA on nitrate issues. EPA will send letter in November 2013.

